

**CITY OF JACKSON
CITY HALL ROOF REPAIR BID
ADDENDUM 2
AUGUST 6, 2020**

Q&A

Can the new pol-iso cover board be mechanically fastened or must it be glued down?

The new poly-iso may be mechanically fastened and the membrane shall be glued down.

What is the time frame for project completion?

Project shall be completed within 90 days of awarding of bid.

Are there any liquidated damages?

No.

DATE OF BID OPENING: AUGUST 12, 2020 AT 10:30 A.M.

ACKNOWLEDGE RECEIPT OF ADDENDA 1 AND 2 IN YOUR BID