

City of Jackson, TN

Addendum 1

July 29, 2020

City Hall Roof Repair Pre-Bid Meeting

In attendance:

Devilon Young (City of Jackson)	dyoung@jacksontn.gov	731-467-6142
Greg Hatmaker (Best Choice Roofing)	g_hatmaker@yahoo.com	931-305-8283
Mitch Parker (Strickland Roofing)	stri0869@bellsouth.net	731-424-7496
Eric Sills (Elite Contractors)	esills@bellsouth.net	731-225-4486

Q&A

Is the silicone coating required to be reapplied to the new roofing?

No.

Is the decking metal or concrete?

Metal decking is in place.

Installing a new cover board and glue down?

Yes. New poly-iso cover board to be installed under membrane.

Location for setting up crane?

You will be allowed to set up on Main Street (about half of a day).

Can traffic control be provided by the City?

We will block off Main Street for about half of the day to provide time for the crane to raise materials to the roof.